



RECEIVED

03 OCT 2007

Certificate of Compliance

Certificate: 1136420 (LR 79122-1)

Master Contract: 178434

Project: 1950839

Date Issued: 2007/09/24

Issued to: MEDC Limited

Colliery Rd
Nottingham
Pinxton, NG16 6JF
United Kingdom
Attention: Brian Taylor

The products listed below are eligible to bear the CSA Mark shown



Issued by: Edward Foo, C.E.T.

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 4818 02 - SIGNAL APPLIANCES - Audible - For Hazardous Locations

Class I, Groups A, B, C and D:

- Model DB5 sounder, supply 24V dc, 15 mA max; intrinsically safe when connected through CSA Certified zener barrier rated 28V max, 300 ohms min, or 22V max, 150 ohms min.

APPLICABLE REQUIREMENTS



Certificate: 1136420 (LR 79122-1)

Master Contract: 178434

Project: 1950839

Date Issued: 2007/09/24

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations



Supplement to Certificate of Compliance

Certificate: 1136420

Master Contract: 178434

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1950839	2007/09/24	Update to cover minor drawings revisions
History		
1261911	January 3, 2002	Update to include revised printed circuit board and diagrams.
1165202	January 30, 2001	Update to include revised printed circuit board and diagrams.
1136420	December 28, 2000	Addition of alt. revised printed circuit board and diagrams.
-3	October 25, 1996	Addition of alt. marking drawing for Private Labeling.
-1	January 25, 1992	Original Certification.