

# Loss Prevention Certification Board



## This is to certify

**SIEMENS SWITZERLAND LTD  
BUILDING TECHNOLOGIES GROUP**  
Gubelstrasse 22, CH-6301 Zug, Switzerland

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

**DO1101A, DO1101A-Ex, DO1131A, DO1151A, DO1152A, DOT1131A,  
DOT1151A, DOT1151A-Ex and DOT1152A photoelectric smoke detectors**  
(refer to attached appendix for details)

which have complied with the requirements of the following:

**EN 54-7: 2000 + A1: 2002 - Fire detection and fire alarm systems - Smoke detectors –  
Point detectors using scattered, transmitted light or ionization**


Certificate No. 126am(cl-1)

Issue No. 01

Date of Issue 15 February 2007

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please  
visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB



Name: E MATTIE-SULEIMAN

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions  
and is maintained and held in force through regular surveillance activities.

# Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 126am(cl-1)

## SIEMENS SWITZERLAND LTD, BUILDING TECHNOLOGIES GROUP

Products		LPCB Ref. No.
DO1101A	conventional photoelectric smoke detector (DB1101A base)	126am/01
DO1101A-Ex	intrinsically safe conventional photoelectric smoke detector (DB1101A base)	126am/02
DO1131A	addressable photoelectric smoke detector (DB1131A base) <i>Note: Meets EN54-7: 2000 at Standard and High sensitivity settings</i>	126am/03
DO1151A	addressable photoelectric smoke detector (DB1151A base) <i>Note: Meets EN54-7: 2000 at Personen/life sensitivity settings</i>	126am/04
DO1152A	addressable photoelectric smoke detector (DB1151A base) <i>Note: Meets EN54-7: 2000 at Personen/life and Immobilien/property sensitivity settings</i>	126am/05
DOT1131A	addressable photoelectric smoke detector with thermal enhancement (DB1131A base) <i>Note: Meets EN54-7: 2000 at Standard and High sensitivity settings</i>	126am/06
DOT1151A	addressable photoelectric smoke detector with thermal enhancement (DB1151A base) <i>Note: Meets EN54-7: 2000 at Personen/life and Immobilien/property sensitivity settings</i>	126am/07
DOT1151A-Ex	intrinsically safe addressable photoelectric smoke detector with thermal enhancement (DB1151A) <i>Note: Meets EN54-7: 2000 at Personen/life and Immobilien/property sensitivity settings</i>	126am/08

Continued . .

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

Page 2 of 3

Date of Issue 15 February 2007


Issue No. 01

Name: E MATTIE-SULEIMAN

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

# Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 126am(cl-1)

## SIEMENS SWITZERLAND LTD, BUILDING TECHNOLOGIES GROUP

### Products

LPCB Ref.  
No.

DOT1152A      addressable photoelectric smoke detector with thermal enhancement  
(DB1151A base)  
*Note: Meets EN54-7: 2000 at Personen/life and Immobilien/property sensitivity settings*

126am/09

### Bases

DB1101A base  
DB1131A base  
DB1151A base  
DBZ1191 base attachment

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please  
visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN

Page 3 of 3

Date of Issue 15 February 2007

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions  
and is maintained and held in force through regular surveillance activities.